

Rhode Island Department of Health Laboratories

50 Orms Street
Providence RI 02904
Phone: (401) 222-5600 Fax: (401)

- CERTIFICATE OF ANALYSIS -

Analysis Req.**PWSID:** DEM**PWS****Contact** PETER C. NAUMANN
235 PROMENADE ST.
PROVIDENCE

RI 02908

Today's

24-Aug-11

Lab

20110816014

SampleID

776724

Source**Facility****Sample Point****Description:****Collected** PETER C.
Sample Collection 8/16/2011**Collection** PEARL ST. STREAM 010, NORTH**Sample Receipt** 8/16/2011
Sample Completed 8/23/2011**Analytical
Method****Test****Test****Flag****Result****Units****Reportin
g Limit****Analysis
Date****SM9221B,D**

PRESUMPTIVE	SM01	3332000		8/16/2011
CONFIRMED, TOTAL	SM01	3-3-3-2		8/16/2011
FECAL COLIFORM	SM01	3-3-3-0		8/16/2011
DILUTION CODE	SM01	B		8/16/2011
MPN RESULT TOTAL COLIFORM	SM01	11,000		8/16/2011
MPN RESULT FECAL COLIFORM	SM01	2,400		8/16/2011

IDEXX

ENTEROCCI COUNT	SM37	249.5	MPN/100M 10	8/16/2011
-----------------	------	-------	-------------	-----------

State Health Laboratories are certified by the US EPA for the analysis of drinking water for microbiological and chemical contaminants. The Above results and associated QC have been reviewed according to the quality assurance standards and found acceptable unless otherwise indicated below. The results in this COA have been transmitted electronically to the Office of Drinking Water Quality for determination of compliance with Rules and Regulations Pertaining to Drinking Water Supply. For Questions regarding compliance, please call 401-222-6867. Flag Explanation: H - result exceeds the standard (maximum contaminant level, secondary maximum contaminant level or health advisory)

Rhode Island Department of Health Laboratories

50 Orms Street
Providence RI 02904
Phone: (401) 222-5600 Fax: (401)

- CERTIFICATE OF ANALYSIS -

Analysis Req.**PWSID:** DEM**PWS****Contact** PETER C. NAUMANN
235 PROMENADE ST.
PROVIDENCE

RI 02908

Today's

24-Aug-11

Lab

20110816015

SampleID

776725

Source**Facility****Sample Point****Description:****Collected** PETER C.
Sample Collection 8/16/2011**Collection** WOONASQUATUCKET RIVER @**Sample Receipt** 8/16/2011
Sample Completed 8/23/2011**Analytical
Method****Test****Test****Flag****Result****Units****Reportin
g Limit****Analysis
Date****SM9221B,D**

PRESUMPTIVE	SM01	3333000		8/16/2011
CONFIRMED, TOTAL	SM01	3-3-3-2		8/16/2011
FECAL COLIFORM	SM01	3-3-2-1		8/16/2011
DILUTION CODE	SM01	B		8/16/2011
MPN RESULT TOTAL COLIFORM	SM01	11,000		8/16/2011
MPN RESULT FECAL COLIFORM	SM01	1,500		8/16/2011

IDEXX

ENTEROCCI COUNT	SM37	1,553.07	MPN/100M 10	8/16/2011
-----------------	------	----------	-------------	-----------

State Health Laboratories are certified by the US EPA for the analysis of drinking water for microbiological and chemical contaminants. The Above results and associated QC have been reviewed according to the quality assurance standards and found acceptable unless otherwise indicated below. The results in this COA have been transmitted electronically to the Office of Drinking Water Quality for determination of compliance with Rules and Regulations Pertaining to Drinking Water Supply. For Questions regarding compliance, please call 401-222-6867. Flag Explanation: H - result exceeds the standard (maximum contaminant level, secondary maximum contaminant level or health advisory)

Rhode Island Department of Health Laboratories

50 Orms Street
Providence RI 02904
Phone: (401) 222-5600 Fax: (401)

- CERTIFICATE OF ANALYSIS -

Analysis Req.**PWSID:** DEM**PWS****Contact** PETER C. NAUMANN
235 PROMENADE ST.
PROVIDENCE

RI 02908

Today's

24-Aug-11

Lab

20110816016

SampleID

776726

Source**Facility****Sample Point****Description:****Collected** PETER C.
Sample Collection 8/16/2011**Collection** WOONASQUATUCKET RIVER @**Sample Receipt** 8/16/2011
Sample Completed 8/23/2011**Analytical
Method****Test****Test****Flag****Result****Units****Reportin
g Limit****Analysis
Date****SM9221B,D**

PRESUMPTIVE	SM01	3332100		8/16/2011
CONFIRMED, TOTAL	SM01	3-3-3-2		8/16/2011
FECAL COLIFORM	SM01	3-3-3-0-0		8/16/2011
DILUTION CODE	SM01	B		8/16/2011
MPN RESULT TOTAL COLIFORM	SM01	9,300		8/16/2011
MPN RESULT FECAL COLIFORM	SM01	2,300		8/16/2011

IDEXX

ENTEROCCI COUNT	SM37	648.8	MPN/100M 10	8/16/2011
-----------------	------	-------	-------------	-----------

State Health Laboratories are certified by the US EPA for the analysis of drinking water for microbiological and chemical contaminants. The Above results and associated QC have been reviewed according to the quality assurance standards and found acceptable unless otherwise indicated below. The results in this COA have been transmitted electronically to the Office of Drinking Water Quality for determination of compliance with Rules and Regulations Pertaining to Drinking Water Supply. For Questions regarding compliance, please call 401-222-6867. Flag Explanation: H - result exceeds the standard (maximum contaminant level, secondary maximum contaminant level or health advisory)

Rhode Island Department of Health Laboratories

50 Orms Street
Providence RI 02904
Phone: (401) 222-5600 Fax: (401)

- CERTIFICATE OF ANALYSIS -

Analysis Req.**PWSID:** DEM**PWS****Contact** PETER C. NAUMANN
235 PROMENADE ST.
PROVIDENCE

RI 02908

Today's

24-Aug-11

Lab

20110816017

SampleID

776728

Source**Facility****Sample Point****Description:****Collected** PETER C.
Sample Collection 8/16/2011**Collection** GILLEN ST. PIPE 005 A**Sample Receipt** 8/16/2011
Sample Completed 8/23/2011**Analytical
Method****Test****Test****Flag****Result****Units****Reportin
g Limit****Analysis
Date****SM9221B,D**

PRESUMPTIVE	SM01	3332210		8/16/2011
CONFIRMED, TOTAL	SM01	3-3-3-2-1-0		8/16/2011
FECAL COLIFORM	SM01	3-3-3-1-0-0		8/16/2011
DILUTION CODE	SM01	B		8/16/2011
MPN RESULT TOTAL COLIFORM	SM01	15,000		8/16/2011
MPN RESULT FECAL COLIFORM	SM01	4,300		8/16/2011

IDEXX

ENTEROCCI COUNT	SM37	2,419.17	MPN/100M 10	8/16/2011
-----------------	------	----------	-------------	-----------

State Health Laboratories are certified by the US EPA for the analysis of drinking water for microbiological and chemical contaminants. The Above results and associated QC have been reviewed according to the quality assurance standards and found acceptable unless otherwise indicated below. The results in this COA have been transmitted electronically to the Office of Drinking Water Quality for determination of compliance with Rules and Regulations Pertaining to Drinking Water Supply. For Questions regarding compliance, please call 401-222-6867. Flag Explanation: H - result exceeds the standard (maximum contaminant level, secondary maximum contaminant level or health advisory)

Rhode Island Department of Health Laboratories

50 Orms Street
Providence RI 02904
Phone: (401) 222-5600 Fax: (401)

- CERTIFICATE OF ANALYSIS -

Analysis Req.**PWSID:** DEM**PWS****Contact** PETER C. NAUMANN
235 PROMENADE ST.
PROVIDENCE

RI 02908

Today's

24-Aug-11

Lab

20110816018

SampleID

776729

Source**Facility****Sample Point****Description:****Collected** PETER C.
Sample Collection 8/16/2011**Collection** GILLEN ST. PIPE 005 B**Sample Receipt** 8/16/2011
Sample Completed 8/23/2011**Analytical
Method****Test****Test****Flag****Result****Units****Reportin
g Limit****Analysis
Date****SM9221B,D**

PRESUMPTIVE	SM01	3331000		8/16/2011
CONFIRMED, TOTAL	SM01	3-3-3-1		8/16/2011
FECAL COLIFORM	SM01	3-3-3-0		8/16/2011
DILUTION CODE	SM01	B		8/16/2011
MPN RESULT TOTAL COLIFORM	SM01	4,600		8/16/2011
MPN RESULT FECAL COLIFORM	SM01	2,400		8/16/2011

IDEXX

ENTEROCCI COUNT	SM37	410.6	MPN/100M 10	8/16/2011
-----------------	------	-------	-------------	-----------

State Health Laboratories are certified by the US EPA for the analysis of drinking water for microbiological and chemical contaminants. The Above results and associated QC have been reviewed according to the quality assurance standards and found acceptable unless otherwise indicated below. The results in this COA have been transmitted electronically to the Office of Drinking Water Quality for determination of compliance with Rules and Regulations Pertaining to Drinking Water Supply. For Questions regarding compliance, please call 401-222-6867. Flag Explanation: H - result exceeds the standard (maximum contaminant level, secondary maximum contaminant level or health advisory)

Rhode Island Department of Health Laboratories

50 Orms Street
Providence RI 02904
Phone: (401) 222-5600 Fax: (401)

- CERTIFICATE OF ANALYSIS -

Analysis Req.**PWSID:** DEM**PWS****Contact** PETER C. NAUMANN
235 PROMENADE ST.
PROVIDENCE

RI 02908

Today's

24-Aug-11

Lab

20110816019

SampleID

776730

Source**Facility****Sample Point****Description:****Collected** PETER C.
Sample Collection 8/16/2011**Collection** GILLEN ST. PIPE 005 C**Sample Receipt** 8/16/2011
Sample Completed 8/23/2011**Analytical
Method****Test****Test****Flag****Result****Units****Reportin
g Limit****Analysis
Date****SM9221B,D**

PRESUMPTIVE	SM01	3333333		8/16/2011
CONFIRMED, TOTAL	SM01	3333333		8/16/2011
FECAL COLIFORM	SM01	3333331		8/16/2011
DILUTION CODE	SM01	B		8/16/2011
MPN RESULT TOTAL COLIFORM	SM01	>=24,000,000		8/16/2011
MPN RESULT FECAL COLIFORM	SM01	4,600,000		8/16/2011

IDEXX

ENTEROCCI COUNT	SM37	>2,419.2	MPN/100M 10	8/16/2011
-----------------	------	----------	-------------	-----------

State Health Laboratories are certified by the US EPA for the analysis of drinking water for microbiological and chemical contaminants. The Above results and associated QC have been reviewed according to the quality assurance standards and found acceptable unless otherwise indicated below. The results in this COA have been transmitted electronically to the Office of Drinking Water Quality for determination of compliance with Rules and Regulations Pertaining to Drinking Water Supply. For Questions regarding compliance, please call 401-222-6867. Flag Explanation: H - result exceeds the standard (maximum contaminant level, secondary maximum contaminant level or health advisory)

Rhode Island Department of Health Laboratories

50 Orms Street
Providence RI 02904
Phone: (401) 222-5600 Fax: (401)

- CERTIFICATE OF ANALYSIS -

Analysis Req.**PWSID:** DEM**PWS****Contact** PETER C. NAUMANN
235 PROMENADE ST.
PROVIDENCE

RI 02908

Today's

24-Aug-11

Lab

20110816020

SampleID

776731

Source**Facility****Sample Point****Description:****Collected** PETER C.
Sample Collection 8/16/2011**Collection** VOLTURNO ST. PIPE 001**Sample Receipt** 8/16/2011
Sample Completed 8/23/2011**Analytical
Method****Test****Test****Flag****Result****Units****Reportin
g Limit****Analysis
Date****SM9221B,D**

PRESUMPTIVE	SM01	3331000		8/16/2011
CONFIRMED, TOTAL	SM01	3-3-3-0		8/16/2011
FECAL COLIFORM	SM01	3-3-2-0		8/16/2011
DILUTION CODE	SM01	B		8/16/2011
MPN RESULT TOTAL COLIFORM	SM01	2,400		8/16/2011
MPN RESULT FECAL COLIFORM	SM01	930		8/16/2011

IDEXX

ENTEROCCI COUNT	SM37	325.5	MPN/100M 10	8/16/2011
-----------------	------	-------	-------------	-----------

State Health Laboratories are certified by the US EPA for the analysis of drinking water for microbiological and chemical contaminants. The Above results and associated QC have been reviewed according to the quality assurance standards and found acceptable unless otherwise indicated below. The results in this COA have been transmitted electronically to the Office of Drinking Water Quality for determination of compliance with Rules and Regulations Pertaining to Drinking Water Supply. For Questions regarding compliance, please call 401-222-6867. Flag Explanation: H - result exceeds the standard (maximum contaminant level, secondary maximum contaminant level or health advisory)